



Texas Commission on Environmental Quality

Protecting Texas by Reducing and Preventing Pollution

October 08, 2025

Delivered Via Certified Mail DWQ/NOV/02/2950

CITY OF CHILDRESS
CAREY PRESTON, MAYOR
PO BOX 1087
CHILDRESS, TX 79201-1087

SUBJECT: Notice of Violation: TOTAL TRIHALOMETHANE (TTHM) MCL, LRAA
30 TAC §290.115(f) - MCL Based on Locational Running Annual Average (LRAA)
CITY OF CHILDRESS - PWS ID NO. TX0380001
CHILDRESS County, TX

This letter contains important information about compliance requirements for your public water system.

Attention: Public Water System Owner / Manager / Operator

The Texas Commission on Environmental Quality (TCEQ) has determined that CITY OF CHILDRESS has violated the maximum contaminant level (MCL) for total trihalomethanes in the water supplied to its customers. This violation occurred during quarter three 2025. Title 30 Texas Administrative Code (30 TAC) §290.115 describes how we determined that this violation occurred.

The MCL for total trihalomethanes is 0.080 milligrams per liter (mg/L) based on a locational running annual average (LRAA). From the data contained in the attached report, we determined a compliance value for total trihalomethanes in quarter three 2025 of 0.118 mg/L for DBP2-02.

Your public water system is required to issue public notification to your customers about the MCL violation as soon as possible, but no later than 30 days after the date the violation was identified in accordance with 30 TAC §290.122. You are required to repeat the notice every three months for as long as the violation persists. You should use the same method that you used for the initial notice. The TCEQ recommends that the public water system provide a copy of the Public Notice(s) to local and state officials, such as Mayors, City Council Members, County Commissioners, Judges, and/or State Representatives, that are located in or that represent the affected area(s) served by the system.

The public notice must use the enclosed mandatory language for every notice, and include a brief statement about how you plan to address the problem as described in 30 TAC §290.122(d). This statement must describe what actions the water system is taking to correct the violation and when the water system expects to return to compliance. Please send a copy of the public notification and a signed Certificate of Delivery for Public Notice to this office within 10 days after it has been delivered. Mail to:

Drinking Water Inventory and Protection Team
TCEQ Public Drinking Water (MC-155)
P.O. Box 13087
Austin TX 78711-3087

Please note that enforcement actions resulting from noncompliance may result in fines for each violation.

To view your public water system information, including the status of your violation(s), and public notice requirements, visit Texas Drinking Water Watch at:
<<http://dww2.tceq.texas.gov/DWW/>>

If you have not already done so, we encourage you to seek assistance. One form of assistance we can offer is through the TCEQ Directed Assistance Contract that is designed to offer free assistance to public water supplies in financial, managerial and technical areas. Please call the financial, managerial, and technical (FMT) assistance program at (512) 239-4691 and ask for a referral for "MCL violation directed assistance." If you would prefer, you can contact a member of the Drinking Water Quality Team at PWSChem@tceq.texas.gov to assist you with this referral.

If you have questions regarding this **MCL violation**, please contact:

Drinking Water Standards Section, Drinking Water Quality Team
Phone: (512) 239-1064
Email: PWSChem@tceq.texas.gov

If you have questions regarding **public notice requirements**, please contact:

Kristine Krieg, Public Notice Compliance Coordinator
Phone: 512-239-5723
Fax: (512) 239-3666
Email: PWSNOTICE@tceq.texas.gov

Sincerely,



Laura Higgins, Section Manager
Drinking Water Standards Section
Water Supply Division
Texas Commission on Environmental Quality

LH/av
Enclosures
cc: TCEQ Region 1

KEVIN L HODGES, CITY MANAGER PO BOX 1087 CHILDRESS, TX 79201-1087

Violation Sample Results Report:
CITY OF CHILDRESS PWS ID: TX0380001

DBP2-02

Violation ID Number	Monitoring Period	Violation Description	Analyte Description	Calculated Compliance Value
717	3Q2025	MCL, LRAA	TTHM	0.118 mg/L

Results for Quarter 3 of 2025: TTHM

Sample ID:Q2536824002 09/09/2025 DBP2-02 811 J SOUTH EAST, CHILDRESS 189.0 µg/L

Results for Quarter 2 of 2025: TTHM

Sample ID:Q2520507001 05/27/2025 DBP2-02 811 J SOUTH EAST, CHILDRESS 38.5 µg/L

Results for Quarter 1 of 2025: TTHM

Sample ID:Q2509356002 03/11/2025 DBP2-02 811 J SOUTH EAST, CHILDRESS 35.4 µg/L

Results for Quarter 4 of 2024: TTHM

Sample ID:Q2452915001 12/11/2024 DBP2-02 811 J SOUTH EAST, CHILDRESS 209.0 µg/L

**Mandatory Language for a Maximum Contaminant Level Violation
MCL, LRAA / TTHM**

The Texas Commission on Environmental Quality (TCEQ) has notified the CITY OF CHILDRESS TX0380001 that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for total trihalomethanes. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for total trihalomethanes to be 0.080 milligrams per liter (mg/L) based on locational running annual average (LRAA), and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for total trihalomethanes indicates a compliance value in quarter three 2025 of 0.118 mg/L for DBP2-02.

Trihalomethanes are a group of volatile organic compounds that are formed when chlorine, added to the water during the treatment process for disinfection, reacts with naturally-occurring organic matter in the water.

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidney, or central nervous systems, and may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

We are taking the following actions to address this issue:

<corrective actions>

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact _____ at
_____ <water system official's name>
<area code + phone number>

Posted /Delivered on: _____
<Date Posted>

Instructions for preparing the required Public Notice:

Recopy the mandatory language above and insert the underlined information in the spaces indicated.

The TCEQ recommends that the public water system provide a copy of the Public Notice(s) to local and state officials, such as Mayors, City Council Members, County Commissioners, Judges, and/or State Representatives, that are located in or that represent the affected area(s) served by the system.

Public Notice delivery timelines:

The initial public notice shall be issued as soon as possible, but in no case later than 30 days after the violation was identified. Repeat public notice shall be issued every 90 days for as long as the violation persists. All notifications require the attached Certificate of Delivery due 10 days from the posting date of the above notice.

Refer to 30 TAC §290.122 for additional information on Public Notification.



Texas Commission on Environmental Quality
Protecting Texas by Reducing and Preventing Pollution

CERTIFICATE OF DELIVERY OF PUBLIC NOTICE TO CUSTOMERS

Public Water System (PWS)-name: **CITY OF CHILDRESS**

PWS ID (7-digit number required): **TX0380001**

Type violation: **TTHM MCL, LRAA**

Time Period of violation: **third quarter of 2025**

The PWS named above has distributed the Public Notice (PN) for the type of violation and time period listed above by:

Mail or direct delivery, to bill-paying customers as required by 30 TAC §290.122(b)(2)(A) for community water systems; and

The information contained in this public notification is correct and complies with required public notification content in accordance with 30 TAC §290.122 and;

Made an adequate good-faith effort to reach non-bill-paying consumers by appropriate methods (check all below that apply):

- ☐ Posting the PN on the internet at www.
- ☐ Mailing the PN to postal patrons within the service area that do not receive a bill
- ☐ Advertising the PN in news media
- ☐ Publication of PN in local newspaper
- ☐ Posting the PN in public places
- ☐ Delivery of multiple copies to single bill addresses serving several persons
- ☐ Delivery to community organizations
- ☐ Email notification

Date of Delivery to Customers _____

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations."

Certified by: Name (print): _____ Title: _____
Phone: _____
Signature: _____ Date Signed: _____

Mail a copy of this completed form and a copy of the Public Notice that was delivered to your customers to:

TCEQ - Drinking Water Inventory & Protection Team
Attn: Public Notice (MC-155)
P. O. Box 13087
Austin, TX 78711-3087